

C E R T I F I C A T E



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50402139 0001

Report No.: 15044695 002

Holder: Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing, Zhejiang Province 325603
P. R. China

Product: Auxiliary Contacts
(Auxillary Contact)

Identification: Type Designation : AX-1
Ratings : AC-12: 3A(415V)
DC-12: 1A(125V)
In: 1kA; Ui: 500V

Remark:
Refer to test report 15044695 001-002 for details.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Date 22.03.2018



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. **CE**

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50402141

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*

B.W.

Unser Zeichen *Our Reference*

01-DY-15044695 002

Ausstellungsdatum

22.03.2018

Date of Issue

(day/mo/yr)

Genehmigungsinhaber *License Holder*

Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing, Zhejiang Province 325603
P. R. China

Fertigungsstätte *Manufacturing Plant*

Zhejiang Chint Electrics Co., Ltd.
No.1,
Chint Road, Chint Industrial Zone,
North Baixiang
Yueqing, Zhejiang Province 325603
P. R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60947-5-1:2017

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzen gelte - Einheit
License Fee - Unit

Auxiliary Contacts (Auxiliary Contact)

Type Designation : AX-1

5

Utilization Category: Rated Operational Voltage/Current

AC-12: AC415V/3A;
DC-12: DC125V/1A;

Conventional Free Air

Thermal Current : 3A

rated insulation voltage : 500V

rated conditional

short-circuit current : 1kA

IP code : IP20

5

ANLAGE (Appendix) : 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety





Ref. Certif. No.

CN61055

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Name and address of the applicant

Auxiliary Contacts

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the manufacturer

Zhejiang CHINT Electrics Co., Ltd.

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.

Note: When more than one factory, please report on page 2

No.1, CHINT Road, CHINT Industrial Zone, North Baixiang
Town, Yueqing City, Zhejiang Province, P.R.China

Ratings and principal characteristics

Ui:500V;Uimp:4kV;Ith:6A;AC-12:Ue/Ie:AC415V/3A,AC240V
/6A; DC-12:Ue/Ie:DC130V/1A,DC48V/2A,DC24V/6A;IP20

Trademark (if any)

CHINT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

AX-X1,AL-X1,AX-X1H,AL-X1H,AXF-X1,ALF-X1;

Additional information (if necessary may also be
reported on page 2)

IEC 60947-5-1:2016(4th Edition)

A sample of the product was tested and found
to be in conformity with

00901-CB2023CQC-108357

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Aug.09,2023

Signature: 
Xie ZhaoXu





www.npower.com.vn

Tài liệu được tổng hợp bởi đội ngũ kỹ thuật của **NPOWER**

Bản quyền nội dung thuộc về công ty **Chint Global**

Powered by **NAVITECH** | www.navitech.co



www.npower.com.vn

Tài liệu được tổng hợp bởi đội ngũ kỹ thuật của **NPOWER**

Bản quyền nội dung thuộc về công ty **Chint Global**

Powered by **NAVITECH** | www.navitech.co